



Certificate of Compliance

Certificate: 70111114

Master Contract: 261400

Project: 80104173

Date Issued: 2022-01-26

Issued To: Fay Mekanik Makine San Ve Tic Ltd Sti.
Kucukcamlica Mahallesi
Güler Sokak, No 1/B
Üsküdar, İstanbul, 34696
Turkey

Attention: Ibrahim Colak

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: Bret Ekstrand
Bret Ekstrand



PRODUCTS

CLASS - C333503 - SYSTEMS (GAS) Earthquake Valves and Earthquake Actuated Automatic Shutoff

CLASS - C333583 - SYSTEMS (GAS)-Earthquake Valves and Earthquake Actuated Automatic Shutoff-

Certified to U.S. Standards

Model Number

For Use With Natural and Liquefied Petroleum Gases

Size

Trade Name: FAY

FM-S(200,201)

3/4 x 3/4

FM-S(250,251)

1 x 1



Certificate: 70111114
Project: 80104173

Master Contract: 261400
Date Issued: 2022-01-26

APPLICABLE REQUIREMENTS

ASCE 25-16	Earthquake – Actuated Automatic Gas Shutoff Devices
ANSI Z21.21-2005/CSA 6.5-2005	Automatic Gas Valves
CR90-002	Earthquake Actuated Automatic Gas Shutoff System

Notes:

Products certified under Class C333503, C333583 have been certified under CSA's ISO/IEC 17065 accreditation with the American National Standards Institute (ANSI).
www.ansi.org



Products certified under Class C333503, C333583 have been certified under CSA's ISO/IEC 17065 accreditation with the American National Standards Institute (ANSI).
www.ansi.org





Supplement to Certificate of Compliance

Certificate: 70111114

Master Contract: 261400

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80104173	2022-01-26	Design series complies with ASCE 25-16.
70179090	2018-03-30	Remove ANSI Z21.21b-2011*CSA 6.5b-2011 reference from Applicable Requirements section.
70111114	2017-03-24	Original certification of Nos. FM-S(200,201,250,251). Dwg. Nos. 1-40.